

To: Jeff Cooper[jcooper@zahl-pmc.com]
Cc: Restaino, Mark[restaino.mark@epa.gov]
From: Scott Hansen
Sent: Tue 6/10/2014 4:40:50 PM
Subject: RE: Message from "ricohscanner"

Jeff,

I discussed filling the UST at Izaty's with Mark Restaino, that's fine with the following conditions:
Line tightness test and functionality test be conducted within the next two weeks, start SIR immediately
and conduct CP test prior to
9/3/2014.

In addition, I will work with them on conducting manual tank gauging in the winter time.

Any questions, please call, I will also be contacting Steve at Izaty's.

Thanks,

Scott Hansen

-----Original Message-----

From: Jeff Cooper [mailto:jcooper@zahl-pmc.com]
Sent: Friday, June 06, 2014 2:28 PM
To: Scott Hansen
Subject: FW: Message from "ricohscanner"

Scott,

Here are the last test results and my ph# 612-331 8550. They want to drop 500 gallons on Tuesday, Please advise.

Thank you ,Jeff

-----Original Message-----

From: scanner@zahl-pmc.com [mailto:scanner@zahl-pmc.com]
Sent: Friday, June 06, 2014 1:52 PM
To: Jeff Cooper
Subject: Message from "ricohscanner"

This E-mail was sent from "ricohscanner" (Aficio MP 4002).

Scan Date: 06.06.2014 13:51:38 (-0500)

Queries to: scanner@zahl-pmc.com